



181 US Hwy 46
Mine Hill, NJ 07803
(908) 654-8068
(800) 783-0567
Fax 908-654-8069

LEAD IN DRINKING WATER REPORT

Performed At:

Voorhees High School
North Hunterdon High School

Performed For:

North Hunterdon-Vorhees Regional High School District
Rob Sabo
1445 State Route 31 South, Annandale, NJ, 08801

Prepared By:

LEW Environmental Services, LLC.
181 US Hwy 46
Mine Hill, NJ 07803

Phone (908) 654-8068
Fax (908) 654-8069
Website <http://www.LEWCorp.com>

Inspection Date: 09/09/2025
Project Number: 3810

Table of Contents

Contact Information	3
Introduction	4
Sampling Methodology	4
Drinking Water Results	5
Recommendations	5
Additional Recommendations	5

Appendices


Appendix A	Exceedances
Appendix B	Recommendations
Appendix C	All results
Appendix D	Floor Plan(S)
Appendix E	Water Outlet Inventory(ies)
Appendix F	Laboratory Data

Contact Information

Education Agency

Client Contact:	Rob Sabo
Client Name:	North Hunterdon-Vorhees Regional High School District
Street Address	1445 State Route 31 South, Annandale, NJ, 08801
Phone Number:	908-638-2152

Sampler(s)

Site Assessor(s):	Erick Ulloa
Signature:	
Date:	October 01, 2025

Firm

Organization:	LEW Environmental Services, LLC.
Certification #:	NJDCA 00015 E
Street:	181 US Hwy 46
City, State & Zip:	Mine Hill, NJ 07803
Phone Number:	908-654-8068
Web Address:	http://www.lewcorp.com

Laboratory

Organization:	Environmental Hazard Services, LLC
Street:	7469 Whitepine Road
City, State & Zip:	Richmond, VA 23237
NJDEP Certification #	VA008
Phone Number:	800-347-4010

Introduction

LEW Environmental Services, LLC. was contracted by North Hunterdon-Vorhees Regional High School District to test for the presence of lead in drinking water in two facilities in the district.

Sampling Methodology

LEW Environmental Services, LLC. followed NJAC 6A:26. Full details on sampling practices can be found in Districts Sampling Plan.

All samples were collected in 250mL wide mouth plastic containers that was prepackaged by the analytical laboratory. The sample containers may contain nitric acid, if expedited analysis is required. If not, nitric acid will be added to each sample upon arrival at the laboratory. At each sample location, the first draw sample was taken after it was determined that the water had been standing in the plumbing system for greater than eight hours but less than forty-eight hours. If second draw samples were collected, they were collecting following a flushing protocol outlined in the District's Sampling Plan.

Drinking Water Results

On September 19, 2025, LEW Environmental Services, LLC. returned to collect the following number of post-remediation samples:

North Hunterdon

- 1 post-remediation samples collected plus 1 QAQC blank sample
- 0 samples above the 15ppb action level

Voorhees

- 2 post-remediation samples collected plus 1 QAQC blank sample
- 0 samples above the 15ppb action level

The complete list of samples that exceeded the 15ppb limit can be found in Appendix A. The complete list of all sample results can be found in Appendix C. The laboratory results can be found in Appendix F.

Certain outlets could not or were not tested due to various reasons. The following table lists those locations and the reason why samples were not collected.

School	Sample Location	Reason for not testing.
None		

Recommendations

On September 19, 2025, LEW Environmental Services, LLC. collected the post-remediation samples. We recommend the following actions.

Those outlets where the post remediation sample tested below 15ppb are not considered to be elevated and remediation was effective.

For those outlets where the post remediation draw sample exceeds 15ppb, contact LEW Environmental services for next step recommendations.

Additional Recommendations

- 1) Follow-up samples should be collected after any remediation efforts in order to determine the efficacy of the work.
- 2) Any of the inoperable/non-functioning outlets listed above that are brought back into service should be sampled.
- 3) Comply with all requirements set forth in NJAC 6A:26.

Appendix A Exceedances

Appendix B Recommendations

Appendix C All Results

Building	DateCollected	AnalysisDate	Sample ID	Sample Description	Concentration (ppb)
North Hunterdon HS	9/10/2025	9/18/2025	41-NHRHS-S	SNACK BAR SINK	<1.00
North Hunterdon HS	9/10/2025	9/18/2025	NHRHS-SR	SUNROOM	<1.00

Building	DateCollected	AnalysisDate	Sample ID	Sample Description	Concentration (ppb)
Voorhees HS	9/9/2025	9/18/2025	3-VHS-S	NURSE SINK	3.1
Voorhees HS	9/9/2025	9/18/2025	12-VHS-S	KITCHEN SINK	3.02
Voorhees HS	9/9/2025	9/18/2025	VHS-SR	SUNROOM	<1.00

Appendix D Floor Plan(s)

Appendix E Water Outlet Inventory(ies)

Appendix F Laboratory Data



7469 Whitepine Rd
North Chesterfield, VA 23237
Telephone: 800.347.4010

Lead in Drinking Water Analysis Report

Client: LEW Corp
181 US Hwy 46
Mine Hill, NJ 07803

Report Number: 25-09-02835

Received Date: 09/12/2025
Reported Date: 09/19/2025
Sampled By: Erick Ulloa
Tech Certification #:

Project/Test Address: 3810; Voorhees HS; 256 County Rd 513; Glen Garden, NJ 08826

Client Number:
201327

Laboratory Results

Fax Number:
Ext 18 Melissa

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
25-09-02835-001	3-VHS-S	09/09/2025	NURSE SINK	3.10	09/18/2025	
25-09-02835-002	12-VHS-S	09/09/2025	KITCHEN SINK	3.02	09/18/2025	
25-09-02835-003	VHS-SR	09/09/2025	SUNROOM	<1.00	09/18/2025	

Method: EPA 200.8
Analyst: Nicole Holloway
Accreditation #: NJ VA008

Reviewed By Authorized Signatory:

Melissa Kanode

Melissa Kanode

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND ug/L= micrograms per liter ppb = parts per billion

**ENVIRONMENTAL HAZARDS SERVICES, LLC****WaterSmart® Lead Chain-of-Custody Form**Richmond, VA - Phone: (800) 347-4010 FAX: (804) 275-4907
www.leadlab.com

25-09-02835

Due Date:
09/19/2025
(Friday)
AEClient Name: LEW CORP Account #: 201327Address: 181 US HIGHWAY 46City/State/Zip: MINE HILL, NJ 07803Phone: 908-654-8068Email Address: labresults@lewcorp.comProject Name/ Number: 3810; VOORHEES HSCollection Address: 256 COUNTY RD 513
(Required)City/State/Zip: GLEN GARDEN, NJ 08826
(Required)Approx. Age Of Property: _____ Collected By: ERICK ULLOAWater Source: (Check One) Public ☒ or Well _____

Well Tag # (if applicable): _____

Turn-Around Time ☒ 5 Days ☐ 3 Days ☐ 2 Days ☐ 1 Day

No.	Client Sample ID	Collection Location (Ex: Kitchen Sink)	Collection Date	Collection Time	Analyte	
					Pb	Cu
1	3-VHS-S	NURSE SINK	09-09-2025	AM / PM	X	
2	12-VHS-S	KITCHEN SINK	I	AM / PM	X	
3	VHS-SR	SUNROOM		AM / PM	X	
4				AM / PM	X	
5				AM / PM	X	
6				AM / PM	X	
7				AM / PM	X	
8				AM / PM	X	
9				AM / PM	X	
10				AM / PM	X	
11				AM / PM	X	
12				AM / PM	X	
13				AM / PM	X	
14				AM / PM	X	
15				AM / PM	X	

Released by: ERICK ULLOA

Signature:

Date/Time: 09-09-2025Received by: ELKHUSTRAS

Signature:

Date/Time: 9/12/25 436pm



7469 Whitepine Rd
North Chesterfield, VA 23237
Telephone: 800.347.4010

Lead in Drinking Water Analysis Report

Client: LEW Corp
181 US Hwy 46
Mine Hill, NJ 07803

Report Number: 25-09-02832

Received Date: 09/12/2025
Reported Date: 09/19/2025
Sampled By: Erick Ulloa
Tech Certification #:

Project/Test Address: 3810; North Hunterdon HS; 1445 NJ-31; Annandale, NJ 08801

Client Number:
201327

Laboratory Results

Fax Number:
Ext 18 Melissa

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
25-09-02832-001	41-NHRHS-S	09/10/2025	SNACK BAR SINK	<1.00	09/18/2025	
25-09-02832-002	NHRHS-SR	09/10/2025	SUNROOM	<1.00	09/18/2025	

Method: EPA 200.8
Analyst: Nicole Holloway
Accreditation #: NJ VA008

Reviewed By Authorized Signatory:

Melissa Kanode

Melissa Kanode

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND ug/L= micrograms per liter ppb = parts per billion

**ENVIRONMENTAL HAZARDS SERVICES, LLC****WaterSmart® Lead Chain-of-Custody Form**Richmond, VA - Phone: (800) 347-4010 FAX: (804) 275-4907
www.leadlab.com

25-09-02832

Due Date:
09/19/2025
(Friday)
AE

10+

Phone: 908-654-8068

Client Name: LEW CORP Account #: 201327

Address: 181 US HIGHWAY 46

City/State/Zip: MINE HILL, NJ 07803

Email Address: labresults@lewcorp.com

Project Name/ Number: 3810; North Hunterdon HS

Collection Address: 1445 NJ-31 City/State/Zip: Annandale, NJ 08801
(Required) (Required)

Approx. Age Of Property: Collected By: ERICK ULLOA

Water Source: (Check One) Public ☒ or Well ☐ Well Tag # (if applicable):Turn-Around Time ☒ 5 Days ☐ 3 Days ☐ 2 Days ☐ 1 Day

No.	Client Sample ID	Collection Location (Ex: Kitchen Sink)	Collection Date	Collection Time	Analyte	
					Pb	Cu
1	41-NHRHS-S	SNACK BAR SINK	09-10-2025	AM / PM	X	
2	NHRHS-SR	SUNROOM	L	AM / PM	X	
3				AM / PM	X	
4				AM / PM	X	
5				AM / PM	X	
6				AM / PM	X	
7				AM / PM	X	
8				AM / PM	X	
9				AM / PM	X	
10				AM / PM	X	
11				AM / PM	X	
12				AM / PM	X	
13				AM / PM	X	
14				AM / PM	X	
15				AM / PM	X	

Released by: ERICK ULLOA

Signature:

Date/Time: 09-10-2025

Received by:

Signature:

Date/Time: 9/12/25 428pm